




TOWN OF
VIENNA
Public Works

2023 WATER QUALITY REPORT

TABLE OF CONTENTS

Town of Vienna Contact Information 2
Important Health Information 2
Message from the Town Manager 3
Your Drinking Water Quality 3
Your Drinking Water Sources 4
Source Water Assessment & Protection 6
What is in the Water? 6
What is the Hardness of the Town’s Water? 7
Why is Chlorine Used for Disinfection? 8
Water and Sewer Rates 8
Town of Vienna Water Service Area Map 9
How to Read the Analysis Data 10
Fairfax Water (FCWA) Results 11
Washington Aqueduct (ACOE) Results 12
Town of Vienna Results 14
What is Cryptosporidium? 16
What is Guardia? 17
What is PFAS? 17



TOWN OF VIENNA since 1890

This 2023 Water Quality Report is available online at viennava.gov/2023waterquality.

Town of Vienna PWSID # 6059800

TOWN OF VIENNA CONTACT INFORMATION

- Department of Public Works..... 703-255-6380
Water and Sewer Customer Service..... 703-255-6385
Water and Sewer Division Office..... 703-319-8611
Vienna Non-Emergency Police..... 703-255-6366

ADDITIONAL CONTACTS

- Virginia Department of Health (VDH)
Office of Drinking Water
Culpeper Field Office (CFO) 540-829-7340
Environmental Protection Agency’s
Safe Drinking Water Hotline..... 800-426-4791
EPA Region III
Drinking Water Section..... 215-814-5495

IMPORTANT HEALTH INFORMATION

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. Environmental Protection Agency (EPA)/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.

This report contains important information about your drinking water. If you cannot read English, please have someone who understands this report translate it for you. For more information, contact Town of Vienna Water Resource Engineer Alan Chen by phone at 703-319-8610 or by email at Alan.Chen@viennava.gov.

El informe contiene información importante sobre la calidad del agua en su comunidad. Tradúzcalo o hable con alguien que lo entienda bien.

MESSAGE FROM THE TOWN MANAGER

This is the Town of Vienna's annual report to inform you about your drinking water quality. As part of the Safe Drinking Water Act of 1996, the U.S. Environmental Protection Agency (EPA) requires all water utilities across the nation to provide their customers with a Water Quality Report by July 1 every year. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand our efforts to protect your water supply.

The quality of your drinking water must meet state and federal requirements administered by the Virginia Department of Health (VDH) and EPA. The Town routinely monitors the water supply for various contaminants to ensure that we meet all regulatory requirements. The tables in this report list only those contaminants for which there was some level of detection. Vienna's water was analyzed for many additional contaminants, but either they were not present or were below detection limits of the laboratory equipment. Water quality data is primarily from testing done in 2022; however, the EPA allows us to monitor for some contaminants less than once a year because concentration of these contaminants changes infrequently.

Is your water safe to drink? Absolutely!
We are proud to share our water quality test results with you. For further information, please call a contact number listed on page 2.

Sincerely,



Mercury Payton
Town Manager



GET INVOLVED – PUBLIC MEETINGS

Decisions concerning Vienna's water are made by Town Council. Regular Council meetings generally are held the first and third Monday of each month (except in July and August) at 8 p.m. in Council Chambers at Town Hall.

The Town's meeting and event calendar is available for review at viennava.gov/getting-to-know-vienna/town-calendar.

YOUR DRINKING WATER QUALITY

In the following report, you will find an overview of required and voluntary water testing programs undertaken by the Town of Vienna in order to protect and ensure the quality of our drinking water system. Data presented in this report was collected in 2022 unless otherwise stated in the data tables.

As water travels over land surfaces or through the ground, it dissolves naturally-occurring minerals and can pick up substances resulting from the presence of animals or human activity. Substances (referred to as contaminants) in source water may come from septic systems, discharges from domestic or industrial wastewater treatment facilities, agricultural and farming activities, urban stormwater runoff, residential uses, and many other types of activities. Water from surface sources is treated to make it drinkable. All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

To ensure that tap water is safe to drink, the EPA prescribes regulations limiting the amounts of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water.


WATER QUALITY REPORT

More information can be obtained by calling the EPA’s Safe Drinking Water Hotline at 800-426-4791.

YOUR DRINKING WATER SOURCES

For calendar year 2022, the Town of Vienna was supplied with treated surface water from the Potomac River and Occoquan Reservoir. This water is supplied by the Fairfax County Water Authority (FCWA) and by the Army Corp of Engineers (ACOE) through the Washington Aqueduct. The water is treated at the James J. Corbalis Jr. and Frederick P. Griffith plants, operated by FCWA, and the McMillan and Dalecarlia treatment plants, operated by the ACOE. Water goes through several treatment processes, including coagulation, flocculation, chlorination, sedimentation, and filtration. A corrosion inhibitor is added to help prevent leaching of lead and copper that may be present in household plumbing. Fluoride also is added to protect health. The treated water must meet state and federal requirements.

Assessments of Vienna’s water sources determined that they may be vulnerable to contamination from agricultural activities, residential development, and industry. However, extensive treatment, provided by Fairfax Water and the Army Corps of Engineers, protects the water from contamination. As mentioned elsewhere in this report, the Town of Vienna’s water quality continues to meet all federal and state requirements.





GET INVOLVED – PROTECT YOUR WATER SOURCES

A watershed is an area of land that drains to a particular point along a stream or river. The best way to protect the Potomac River from contamination is to help protect the watershed.

Here are several ways to help protect your drinking water supply:

- **Use less fertilizer.** Test your soil before application and follow the manufacturer's instructions.
- **Apply fertilizer in the fall** to help reduce nitrogen and phosphorus runoff or leaching often caused by heavy spring rains.
- **Leave grass clippings on lawn** as a natural fertilizer.
- **Mow grass to proper height** - three inches is recommended.
- **Plant native or well-adapted plants** that are likely to require less water, fertilizer, and pesticides.
- **Flush pet waste** down the toilet or wrap securely and place in trash.
- **Don't pour chemicals down the drain.** Dispose of household chemicals through a hazardous waste recycling program such as the Fairfax County's Household Hazardous Waste Disposal Program.
- **Don't flush unused pharmaceuticals.** Find a drug take-back location or properly dispose of medication in the garbage.
- **Prevent trash and debris** from entering storm drains and catch basins. To report a clogged drain or basin, call 703-255-6380.
- **Report spills** that could potentially enter waterways by calling 703-255-6380. After regular business hours, call the Vienna police non-emergency number at 703-255-6366.





SOURCE WATER ASSESSMENT AND PROTECTION

Under provisions of the federal Safe Drinking Water Act, states are required to develop comprehensive source water assessment programs that meet the following requirements:

- identify watersheds that supply public tap water,
- provide an inventory of contaminants present in the watershed, and
- assess susceptibility to contamination in the watershed.

The VDH and Interstate Commission on the Potomac River Basin (ICPRB) completed source water assessments for local watersheds. The assessments consist of maps of evaluated watershed areas, an inventory of known land-use activities, and documentation of any known source water contamination within the last five years. Based on criteria developed by the state, the Potomac River and Occoquan Reservoir were determined to be of high susceptibility to contamination. This determination is consistent with the state’s finding for other surface waters, such as rivers, lakes, and streams, throughout the Commonwealth of Virginia. The assessment reports

are available at fairfaxwater.org/swap.

WHAT IS IN THE WATER?

Contaminants that may be in source water include:

Microbial Contaminants (Viruses and Bacteria)	Inorganic Contaminants (Salts and Metals)	Pesticides and Herbicides	Organic Chemical Contaminants	Radioactive Contaminants
<ul style="list-style-type: none"> • Sewage treatment plants • Septic systems • Agricultural livestock operations • Wildlife 	<ul style="list-style-type: none"> • Urban stormwater runoff • Industrial wastewater discharges • Oil and gas production • Mining or farming 	<ul style="list-style-type: none"> • Agriculture • Urban stormwater runoff • Residential uses 	<ul style="list-style-type: none"> • Industrial processes and petroleum production • Gas stations • Urban stormwater runoff • Septic systems 	<ul style="list-style-type: none"> • Oil and gas • Mining activities

The water treatment process makes the Town of Vienna’s water safe to drink!

GET INVOLVED – REDUCING EXPOSURE TO LEAD IN DRINKING WATER

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Vienna is responsible for providing high-quality drinking water but cannot control the variety of materials used in private plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at epa.gov/safewater/lead.

The Town of Vienna’s drinking water does NOT have the same contamination risk as seen in Flint, Michigan. To prevent lead from leaching into drinking water, a phosphate-based corrosion inhibitor is added, and water pH is adjusted by Fairfax Water and the ACOE. The Town’s water distribution system does not contain lead pipes, and there are no identified lead service connections. As part of EPA-mandated lead testing, water from thirty Vienna water service area houses constructed prior to 1986 is periodically tested. These samples have consistently tested below the 0.015 parts per million lead action level as outlined by EPA’s Lead and Copper Rule, and therefore the Town is only required to test for lead every three (3) years. The next round of sampling is scheduled for 2022.

GET INVOLVED – BE FERTILIZER SMART

Smart fertilizer application follows a less is more approach. Fertilizers contain nutrients, like phosphorus and nitrogen, which harm the health and water quality of our local streams and the Chesapeake Bay. Plants can only utilize a certain amount of fertilizer, and the excess washes away with the rain into our streams. Proper management of applied fertilizers and pesticides to lawns and landscapes helps prevent nutrient pollution and protect water quality.

Here are some helpful tips to keep in mind.

- Before applying fertilizer, test soil to determine the correct application rate.
- Fall is the best season to fertilize.
- Never apply fertilizer before it rains.
- For more information, please visit www.viennava.gov



WHAT IS THE HARDNESS OF THE TOWN'S WATER?

Vienna's water can be classified as moderately hard to hard. The historical range on our water hardness is 5 – 10 grains per gallon (80 – 170 mg/L). Hard water is high in dissolved minerals, largely calcium and magnesium. You may have felt the effects of hard water, literally, the last time you washed your hands. Depending on the hardness of your water, after using soap to wash you may have felt like there was a film of residue left on your hands. In hard water, soap reacts with the calcium (which is relatively high in hard water) to form "soap scum". When using hard water, more soap or detergent is needed to get things clean, be it your hands, hair, or your laundry. While hard water is not a health risk. It may, however, be a nuisance causing mineral buildup on fixtures and poor soap and detergent performance. Some people choose to soften their water. Before you soften your water, weigh the benefits of hard water while it can be a valuable source of essential dietary nutrients, like calcium and magnesium. It is less likely to cause pipe corrosion. It often tastes better. Many water softeners operate by adding sodium to the water in exchange for the minerals causing the hardness. This may be a concern for those who must restrict their sodium intake. Consider the options that will work best for you. Additional information on treating water may be found at nsf.org/testing/water/water-treatment.



WHY IS CHLORINE USED FOR DISINFECTION?

Most of the year, chloramine (chlorine + ammonia) is used for drinking water disinfection. For a short period, each year, disinfection switches from chloramine to chlorine. This change is standard practice and is part of an annual program to clean water pipes and maintain water quality throughout the year. During this water chemistry change, chlorine is added in an uncombined state, commonly referred to as free chlorine. Free chlorine is somewhat more volatile than combined chlorine, which allows it to react with suspended sediment. During this change, the Town completes its annual fire hydrant flushing program by opening hydrants and allowing the water to flow freely for a short period of time. This also enables the Town to test and perform routine maintenance on the more than 800 fire hydrants within its service area.



Public water systems use chlorine and chloramine to kill harmful bacteria and viruses that can make people sick. The level of chlorine used is safe for consumption, but you can reduce the chlorine smell and taste by placing an open pitcher of water in the fridge.



GET INVOLVED – HELP PROTECT A FIRE HYDRANT

Winter storms often hide fire hydrants under a mountain of snow, making hydrants impossible to find quickly. In the event of a fire, firefighters have to locate and shovel out buried fire hydrants before hooking up to them, losing precious time that could be better containing a fire and saving lives.

Please do not let your neighborhood hydrant remain under cover of snow, leaves, or other debris. Help your fire department and neighbors by keeping the fire hydrant closest to your residence or business clear of snow, leaves, building debris, and trash. The fire department needs at least three feet of clearance on all sides.

For additional questions or concerns regarding fire hydrants, contact the Town's Department of Public Works at 703-255-6380.

WATER AND SEWER RATES

On May 15, 2023, Town Council adopted the fiscal year 2023-2024 (FY2024) budget. The total FY2024 water and sewer fund budget is set at \$12,246,990. Council also adopted the FY2024 water and sewer rates, which represent increases of 10% each. On July 1, 2023, fixed service charges will increase 6.7% or from \$32.80 to \$35.00 per quarter for all residential customers. For the average Vienna residential customer, this change amounts to approximately \$81.40 per year. This increase is due to increases in sewer treatment, water purchasing, and infrastructure replacement costs and are in line with industry standards. For more information on water and sewer rates, please contact the Town's Water and Sewer Services Customer Care at 703-255-6385 or email water@viennava.gov.

GET INVOLVED – CALL BEFORE YOU DIG

Help protect yourself and our underground utilities by calling 811 before you dig. Whether you are planning to do it yourself or hire a professional, smart digging means calling 811 before each job. More information may be found at va811.com.

TOWN OF VIENNA SERVICE AREA MAP

The Town's water system contains:

- 137 miles of water mains
- 920 fire hydrants
- 9,300 service connections
- 3 storage tanks
- 2,945 water valves

The Town's water system services approximately:

- 16,000 residents inside corporate boundary
- 3,500 customers outside corporate boundary

The Town is a wholesale customer of Fairfax Water and purchases approximately 760 million gallons per year.



WATER SERVICE AREA

TOWN OF VIENNA BOUNDARY

HOW TO READ ANALYSIS DATA

Town of Vienna water is tested to assure that it is safe and healthy. Contaminants in the drinking water are routinely monitored according to federal and state regulations. The tables contained in this report show the most recent results of our monitoring. The “Major Source in Drinking Water” column shows where this substance usually originates. The following definitions are provided to help you better understand terms and abbreviations.

Action Level (AL)

The concentration of a contaminant, which if exceeded, triggers treatment or other requirements that a water system must follow.

EPA (Environmental Protection Agency)

An agency of the United States federal government that protects human health and the environment, including drinking water, by promulgating and enforcing regulations based on laws passed by Congress.

HAA5 (Haloacetic Acids 5)

The five haloacetic acid species required to be monitored by EPA.

Level 1 Assessment

A Level 1 Assessment is a study of waterworks to identify potential problems and, if possible, why total coliform bacteria have been found in a waterworks system.

Level 2 Assessment

A Level 2 Assessment is a very detailed study of waterworks to identify potential problems and determine, if possible, why an E. coli PMCL violation has occurred and why total coliform bacteria have been found in waterworks on multiple occasions.

Maximum Contaminant Level (MCL)

The highest level of a contaminant allowed in drinking water. MCLs are set at very stringent levels by the EPA. In developing standards, EPA assumes that the average adult drinks two liters of water each day throughout a 70-year lifespan. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-one million chance of having the described health effect for other contaminants.

Maximum Contaminant Level Goal (MCLG)

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level (MRDL)

The maximum level of total chlorine allowable by regulation.

Maximum Residual Disinfectant Level Goal (MRDLG)

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of use of disinfectants to control microbial contaminants.

Minimum Detection Limits (DL)

The detection limit is the lowest concentration of a substance that can be determined with confidence. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

Non-Detects (ND)

Laboratory analysis indicates that contaminant is not present.

Not Applicable (NA)

Does not apply to this subject or in this scenario.

Nephelometric Turbidity Unit (NTU)

A measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is monitored because it is a good indicator of the effectiveness of filtration systems.

Picocuries per liter (pCi/L)

A measure of radioactivity in water.

Parts per million (ppm)

One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb)

One part per billion corresponds to half a teaspoon of water in an Olympic-sized swimming pool, one minute in 2,000 years, or one penny in \$10 million.

Treatment Technique (TT)

A required process intended to reduce the level of a contaminant in drinking water.

Turbidity

A measure of the cloudiness of water. We measure turbidity because it is a good indicator of the effectiveness of the water treatment system. Turbidity in excess of 5 NTU is just noticeable to the average person.

FAIRFAX WATER (FCWA) RESULTS - FINISHED WATER CHARACTERISTICS OF REGULATED PARAMETERS

Parameters	Unit	Goal (MCLG)	Max. Allowed (MCL)	Corbalis Water Treatment Plant ¹		Griffith Water Treatment Plant ²		Major Source in Drinking Water
				Minimum	Maximum	Minimum	Maximum	
Barium	ppm	2	2	0.027	0.050	0.032	0.038	Discharge of drilling wastes; discharge from metal refineries; erosion from natural deposits.
Beta/photon emitters ¹	pCi/L	0	50 ³	ND ¹	ND ¹	ND ²	ND ²	Decay of natural and man-made deposits.
Fluoride	ppm	4	4	0.66	0.75	0.63	0.76	Water additive that promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories.
Nitrate (as Nitrogen)	ppm	10	10	0.69	1.35	0.50	1.85	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Nitrite (as Nitrogen)	ppm	1	1	ND	0.012	ND	0.010	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Sodium	ppm	§	§	11.9	24.2	26.7	64.2	Erosion of natural deposits; Runoff from road deicing chemicals; Discharge from industrial sources; Wastewater treatment plant effluent.
Total Organic Carbon	ratio	NA	TT	Removal ratio achieved: 1.1 ⁴ based on quarterly running annual average. Removal ratio range 1.1 – 1.2.		Removal ratio achieved: 1.5 ⁴ based on quarterly running annual average. Removal ratio range 1.3 – 1.5.		Naturally present in the environment.
Turbidity	NTU	NA	TT	0.17 = highest single measurement Lowest monthly percentage of samples meeting turbidity requirements = 100%.		0.35 = highest single measurement Lowest monthly percentage of samples meeting turbidity requirements = 100%.		Soil runoff.

ND = Non detect, below detection level

NA = Non detect, below detection level

ppm = part per million

pCi/L = picocuries per liter

¹ This data was obtained in 2022.

² This data was obtained in 2019.

³ The MCL for the Beta particles is written as 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for Beta particles.

⁴ Quarterly Running Annual Average (QRAA) of the monthly ratio of actual Total Organic Carbon removal versus required Total Organic Carbon removal. QRAA is to be ≥ 1 to be in compliance.

§ There are no State no Federal limits established for this parameter.

WASHINGTON AQUEDUCT (ACOE) RESULTS - FINISHED WATER CHARACTERISTICS OF REGULATED PARAMETERS

Parameters	Unit	Goal (MCLG)	Max. Allowed (MCL)	Dalecarlia Water Treatment Plant		McMillan Water Treatment Plant		Major Source in Drinking Water
				Minimum	Maximum (Highest Detected Level)	Minimum	Maximum (Highest Detected Level)	
Arsenic	ppb	0	10	ND	0.4	ND	0.3	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Atrazine	ppb	3	3	ND	0.2	ND	0.2	Runoff from herbicide used on row crops.
Barium	ppm	2	2	0.05	0.05	0.04	0.04	Discharge of drilling wastes; discharge from metal refineries; erosion from natural deposits.
Beta/Photon emitters ^{1***}	pCi/L	0	50**	ND	4	ND*	3*	Erosion of natural deposits.
Fluoride ¹	ppm	4.0	4.0	0.8	0.8	0.7	0.7	Water additive that promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories.
Nitrate (as Nitrogen)	ppm	10	10	0.8	2	0.5	2	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Total Organic Carbon	ratio	NA	TT	Running annual average removal ratio is required to be equal to or greater than 1.00. Removal ratio actually achieved: ≥1.24 based on running annual averages.		Running annual average removal ratio is required to be equal to or greater than 1.00. Removal ratio actually achieved: ≥1.34 based on running annual averages.		Naturally present in the environment.
Turbidity	NTU	NA	TT	0.19 = highest single hourly measurement. Lowest monthly percentage of samples meeting turbidity requirements = 100%.		0.09 = highest single hourly measurement. Lowest monthly percentage of samples meeting turbidity requirements = 100%.		Soil runoff.

¹ This monitoring was performed in 2020.

* This detect for beta/photon emitters was below the minimum detection limits prescribed in the Consumer Confidence Rule as stated in 40 CFR 141.151 (d) and may not be required for CCR reporting.

** The MCL for beta and photon emitters is 4 mrem/year and EPA considers 50 pCi/L to be the level of concern for beta/photon emitters. Because the beta particle results were below 50 pCi/L, no testing for individual beta particle constituents was required. 40 CFR 141.66(d)(2) specifies average annual tritium concentration of 20,000 pCi/L assumed to produce a total body dose of 4 mrem/yr.

*** The contribution to gross beta (pCi/L) from naturally occurring K-40 isotope is 0.82 times the potassium concentration (mg/L). The concentration of potassium monitored at the Dalecarlia and McMillan WTPs ranged from 2 - 3 mg/L at both WTPs when sampled at the same time as the beta/photon emitter samples. Therefore, the major contributor of gross beta in 2020 may be attributed to naturally-occurring K-40.

Total Organic Carbon has no health effects. However, it provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Compliance with treatment techniques reduces the formation of these disinfection byproducts.

Turbidity levels are measured during the treatment process after the water has been filtered but before disinfection. The turbidity level of filtered water shall be less than or equal to 0.3 NTU in at least 95% of measurements taken each month and shall at no time exceed 1 NTU.

WASHINGTON AQUEDUCT (ACOE) RESULTS - FINISHED WATER CHARACTERISTICS OF UNREGULATED PARAMETERS

Parameters	Unit	Goal (MCLG)	Max. Allowed (MCL)	Dalecarlia Water Treatment Plant		McMillan Water Treatment Plant		Major Source in Drinking Water
				Minimum	Maximum (Highest Detected Level)	Minimum	Maximum (Highest Detected Level)	
Nickel	ppb	§	§	0.7	0.7	ND	ND	Primarily leaching from metals in contact with drinking water, such as pipes and fittings; may also be present in some ground waters as a consequence of dissolution from nickel ore-bearing rocks.
Sodium	ppm	§	§	25	25	31	31	Natural occurrences, road salt, water treatment chemicals, and ion-exchange water softening units.

§There are no State no Federal limits established for this parameter.

TOWN OF VIENNA RESULTS - MICROBIAL INDICATORS

Since 1989, public water systems have been required to comply with the Total Coliform Rule (TCR). A revised version of the rule, the Revised Total Coliform Rule (RTCR), took effect on April 1, 2016. This 2022 Drinking Water Quality Report reflects changes in regulatory requirements imposed by the RTCR. The RTCR maintains the purpose of protecting public health by ensuring the integrity of the drinking water distribution system and monitoring for the presence of microorganisms (i.e., total coliform and E.coli bacteria). The EPA anticipates greater public health protection under the RTCR, as it requires public water systems that are vulnerable to microbial contamination, to identify and fix problems. As a result, under the RTCR, there is no longer a monthly maximum contaminant level violation for multiple total coliform detections. Instead, the RTCR requires public water systems that exceed a specified frequency of total coliform occurrences to conduct an assessment to determine if any sanitary defects exist. If found, these must be corrected.

Parameters	Highest Level Allowed (TT) ¹	Highest Number of Monthly Total Coliform Positive Tests	Assessment Triggered ²	Major Source in Drinking Water
Total Coliform Bacteria	One Total Coliform positive sample per month	4 (November 2022)	Yes	Naturally present in the environment.

Parameters	Highest Level Allowed (EPA MCL)	# of Positive E.coli samples this period	Assessment Triggered ³	Major Source in Drinking Water
E.coli Bacteria	Repeat sample is E.coli positive OR Routine sample is E.coli positive followed by repeat sample that is total coliform positive OR System fails to take all required repeat samples following E.coli positive routine sample OR System fails to analyze for E.coli when any repeat sample tested positive for total coliform	0	No	Human and animal fecal waste.

¹ TT: Treatment Technique (Total Coliform Bacteria was changed from an EPA MCL to a Treatment Technique on April 1, 2016.)

² If greater than one (>1) monthly Total Coliform positive sample percentage is positive, an assessment to determine the cause would be performed and corrective action taken.

³ If an E. coli MCL violation occurs, an assessment to determine the cause would be performed and corrective action taken.

The Town of Vienna had 5 detections of positive total coliform samples out of 383 total samples collected throughout 2022. Under the RTCR, one Level I Assessment was triggered in November 2022. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessments to identify problems and to correct any problems that are found. During the past year, we were required to conduct one Level 1 Assessment, which was completed on December 7, 2022 and meet all requirements of the Waterworks Regulations. The assessment concluded the coliforms present was due to sampling error and adjacent road construction, which may have also been a source of contamination.

Based on the Level 1 Assessment, the positive coliform samples were connected to water main break that may have likely been active at the time testing occurred. One of the samples was taken from an outdoor hose bib that has been winterized and not in recent use. Nearby road construction that may have involved the use of a nearby fire hydrant could also have been the possible source of contamination at two other locations. The Town completed the Level 1 Assessment and no additional positive test results were noted.

TOWN OF VIENNA RESULTS - LEAD AND COPPER

Parameters	Unit	Goal (MCLG)	Action Level	Results of Samples from 90 th Percentile Value	Action Level Exceedance?	# of Sites Exceeding Action Level	Major Source in Drinking Water
Lead	ppb	0	15	0.68	No	0	Corrosion of household plumbing systems; erosion of natural deposits.
Copper	ppm	1.3	1.3	0.113	No	0	

Copper and lead results are based on testing performed in 2022. Due to observed low levels of lead and copper, the Town of Vienna is on a reduced monitoring schedule, which requires monitoring every three years. The next triennial monitoring period is 2025.

TOWN OF VIENNA RESULTS - DISINFECTANTS

Parameters	Unit	Goal (MRDLG) ¹	Max. Allowed (MRDL) ²	Highest Quarterly Average (RAA)	System Range (Individual Results)	Violation	Major Source in Drinking Water
Total Chlorine	ppm	4	4	2.36	0.3 – 4.0	No	Water additive used to control microbes.

¹Maximum Residual Disinfectant Level Goal ²Maximum Residual Disinfectant Level

TOWN OF VIENNA RESULTS – DISINFECTANT BYPRODUCTS

Parameters	Unit	Goal (MCLG) ¹	Max. Allowed (MCL) ¹	Highest Locational Running Annual Average (LRAA) ²	System Range (Individual Results)	Violation	Major Source in Drinking Water
Total Trihalomethanes	ppb	0	80	45	6.16 – 65.00	No	Byproduct of drinking water disinfection.
Haloacetic Acids 5 (HAA5)	ppb	0	60	32	2.77 – 57.40	No	Byproduct of drinking water disinfection.

¹ Unless otherwise specified, MCLG and MCL apply to an individual result. ² Compliance is based upon site-specific Locational Running Annual Averages (LRAAs) (not based upon an individual result).

WHAT IS CRYPTOSPORIDIUM?

Cryptosporidium is a microbial pathogen sometimes found in surface water throughout the United States. Although filtration removes Cryptosporidium, the most commonly used filtration methods cannot guarantee one hundred percent (100%) removal. Fairfax Water consistently maintains its filtration process in accordance with regulatory guidelines to maximize removal efficiency. Fairfax Water monitoring indicates the occasional presence of these organisms in the source water. Current test methods do not allow Fairfax Water to determine whether the organisms are dead or if they are capable of causing disease.

Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, infants and small children, and the elderly are at greater risk of developing life-threatening illness. The Town of Vienna encourages immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection.

Cryptosporidium must be ingested in order to cause disease. It may be spread through means other than drinking water, such as other people, animals, water, swimming pools, fresh food, soils and any surface that has not been sanitized after exposure to feces.

Fairfax Water has completed monitoring the Potomac River and Occoquan Reservoir for compliance with Round 2 of the EPA Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR Round 2). The EPA created this rule to provide for increased protection against microbial pathogens, such as Cryptosporidium, in public water systems that use surface water sources. Fairfax Water’s LT2ESWTR Round 2 monitoring program began in April 2015 and involved the collection of one sample from water treatment plant sources each month for a period of two years. Monitoring for compliance with the LT2ESWTR Round 2 was completed in March 2017.

Under the LT2ESWTR Round 2, the average Cryptosporidium concentration determines whether additional treatment measures are needed. A mean Cryptosporidium concentration of 0.075 oocysts/Liter triggers additional water treatment measures. Fairfax Water’s raw water Cryptosporidium concentrations were below this threshold. Results for LT2ESWTR Round 2 monitoring for the period of 2015-2017 are as follows:

Source (Before Treatment)	Mean Cryptosporidium Concentration (oocysts/Liter)	Final Bin Assignment under LT2ESWTR Round 2
Potomac River	0.000	Bin 1 (No additional treatment required.)
Occoquan Reservoir	0.007	Bin 1 (No additional treatment required.)

Cryptosporidium was monitored in the source water quarterly on January, April, July, and October 2022. Cryptosporidium oocysts were detected in two samples collected at the Great Falls Intake in January and October 2022 at concentrations of 0.0952 and 0.0909 oocysts/L, respectively.

WHAT IS GIARDIA?

Giardia is a microscopic parasite that causes an intestinal illness known as giardiasis. The water treatment process is designed to remove giardia by providing a multiple-barrier approach to chemically treat, filter, and disinfect source water and minimize the risk to public health.

Giardia was monitored in the source water quarterly on January, April, July, and October 2022. Giardia cysts were detected in two samples collected at the Great Falls Intake in January and October 2022 at concentrations of 0.381 and 0.455 cysts/L, respectively.

WHAT IS PFAS?

PFAS (poly- and perfluoroalkyl substances) are a group of over 12,000 man-made chemicals manufactured and used in consumer products such as carpets, clothing, food packaging, and cookware since the 1940s. PFAS are also used in industrial processes such as firefighting foam and waterproofing stains. Most of a person's exposure to PFAS is through food and consumer products and drinking water makes up a small portion of a person's total exposure to PFAS.

On March 14, 2023 the Environmental Protection Agency (EPA) announced new proposed regulations for six different types of PFAS, which is anticipated to be finalized by the end of 2023. In addition to the proposed national drinking water standards, the EPA has also proposed establishing a hazard index for a combination of four other PFAS compounds. The EPA will provide additional information including the time frame when drinking water providers must meet the new standards. The Town of Vienna will carefully monitor these proposed regulations and will work with regional partners to ensure that the Town's water supply continues to meet all EPA and Virginia Department of Health (VDH) standards.

Currently, the Town of Vienna provides water service to 16,000 customers located within Town boundaries and 3,500 outside of Town limits, which is all supplied through Fairfax Water. Fairfax Water has commissioned voluntary PFAS testing since 2023¹ and participated in VDH Occurrence Study completed in 2021. Additional voluntary PFAS occurrence testing will occur in 2023 and Fairfax Water's PFAS testing methodology and results can be found on their website.

The Town of Vienna recognizes safe drinking water is vital in protecting public health and the Town remains confident in our providers' ability to provide safe and reliable drinking water to its customers. The Town will continue to work with our regional partners to continue to provide our customers with the highest quality drinking water.